



City of Madison Fire Department

FIRE PREVENTION DIVISION

325 West Johnson Street, Madison, WI 53703-2295

Phone: 608-266-4420 • Fax: 608-267-1100 • E-mail: fire@cityofmadison.com

Debra H. Amesqua
Fire Chief
608-266-6564

James D. Keiken
Assistant Chief
608-266-5966

Paul T. Bloom
Assistant Chief
608-266-5956

Gregg D. Knudtson
Assistant Chief
608-266-5959

Ernesto Martinez
Division Chief
608-266-4886

Ronald C. Schwenn
Division Chief
608-267-8674

Jeffrey G. Duppler
Division Chief
608-266-4203

Michael D. Popovich
Division Chief
608-266-5946

Arthur B. Price
Division Chief
608-266-4256

Richard A. Kinkade
Division Chief
608-266-4201

Edwin J. Ruckriegel
Fire Marshal
608-266-4457

Rita A. Johnson
Admin Services Mgr.
608-266-5957

Christian C. Zuver
Medical Director
608-266-4424

Fire Investigation
608-266-4488

Visit our website at:
www.madisonfire.org

City of Madison Fire Code

GENERAL PRECAUTIONS AGAINST FIRE SECTION 34.308 OPEN BURNING

IFD section 308.1.4 shall be replaced with the following language:

- (1) Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies within ten (10) feet of combustible construction.
Exceptions:
 - (a) One- and two-family dwellings.
 - (b) Where buildings, balconies and decks are protected by an automatic sprinkler system.

- (2) LP-gas burners having an LP-gas container with a water capacity greater than two and a half (2-½) pounds [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be stored or operated on balconies unless they are served by exterior stairways.
Exceptions:
 - (a) One- and two-family dwellings.
 - (b) Where buildings, balconies and decks are protected by an automatic sprinkler system.